

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
PV 60122202

Blatt *Sheet*
0005

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*

Ausstellungsdatum

Date of Issue

0001--21272343 005

05.09.2019

(day/mo/yr)


Genehmigungsinhaber *License Holder*

FuturaSun srl
Riva del Pasubio 14
35013 Cittadella PD
Italy

Fertigungsstätte *Manufacturing Plant*

Refer to latest revision
of the annex list of factories

Prüfzeichen *Test Mark*



IEC 61215
IEC 61730
Regular Production
Surveillance
www.tuv.com
ID 1111213361

Geprüft nach *Tested acc. to*

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

PV Module

Type:

with 6" mono cells
FUxxxM (xxx = 310-375 in steps of 5, 72 cells)
FUxxxM (xxx = 270-315 in steps of 5, 60 cells)
with 6" poly cells
FUxxxP (xxx = 300-330 in steps of 5, 72 cells)
FUxxxP (xxx = 250-285 in steps of 5, 60 cells)
FUxxxP (xxx = 240-250 in steps of 5, 54 cells)
FUxxxP (xxx = 150-165 in steps of 5, 36 cells)
xxx represent output power in Wp

Remarks:

Max. System Voltage: 1000 VDC or 1500 VDC (Voc at STC).
Class II acc. to IEC 61140
Max. positiv Design Load (downward): 5400 Pa
Max. negativ Design Load (upward): 5400 Pa
including safety factor 1,5.
The above listed PV modules fulfil the requirements of
fire rating class C.

Conditions:

Same as on previous pages
Validity: 8 August 2022

*Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product
fulfills above mentioned requirements, the production is subject to surveillance.*

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 <http://www.tuv.com/safety>

Zertifizierungsstelle



Dipl.-Ing. M. Adrian